



Certificate of Compliance

Certificate: 80097185 **Master Contract:** 603246

Project: 80097185 **Date Issued:** 2021-09-09

Issued to: Wuxi Sunket New Energy Technology Co., Ltd.
No.888, Qinghong Road, Delin Industry Park,
E'Hu Town, Wuxi, Jiangsu, 214117
P.R.China

Attention: Jesse Xia

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: Qiang (Sean) Jiang
Qiang (Sean) Jiang

PRODUCTS

CLASS 5311 10 - POWER SUPPLIES - Photovoltaic Modules and Panels

CLASS 5311 90 - POWER SUPPLIES - Photovoltaic Modules and Panels - Certified to U.S. Standards

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 29, maximum system voltage of 1500 V dc, model series: SKTxxx-72BMH-DG (xxx=350-410, in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 29, maximum system voltage of 1500 V dc, model series: SKTxxx-60BMH-DG (xxx=295-335, in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 29, maximum system voltage of 1500 V dc, model series: SKTxxx-144BMH-DG (xxx=380-470, in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 29, maximum system voltage of 1500 V dc, model series: SKTxxx-120BMH-DG (xxx=325-390, in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 29, maximum system voltage of 1500 V dc, model series: SKTxxx-144BMH-DG (xxx=510-580, in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 29, maximum system voltage of 1500 V dc, model series: SKTxxx-132BMH-DG (xxx=475-520, in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 29, maximum system voltage of 1500 V dc, model series: SKTxxx-120BMH-DG (xxx=430-470, in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 29, maximum system voltage of 1500 V dc, model series: SKTxxx-108BMH-DG (xxx=390-410, in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-72M (72M-BW/72M-BB) (xxx=330-420, in steps of 5), Fuse rating



Certificate: 80097185
Project: 80097185

Master Contract: 603246
Date Issued: 2021-09-09

20A or maximum system voltage of 1500 V dc, model series: SKTxxx-72MH (72MH-BW) (xxx=330-420, in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1, maximum system voltage of 1500 V dc, model series: SKTxxx-72BMH (xxx=350-410, in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-72P (72P-BW/72P-BB) (xxx=310-355, in steps of 5), Fuse rating 20A or maximum system voltage of 1500 V dc, model series: SKTxxx-72PH (72PH-BW) (xxx=310-355, in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-60M (60M-BW/60M-BB) (xxx=275-355, in steps of 5), Fuse rating 20A or maximum system voltage of 1500 V dc, model series: SKTxxx-60MH (60MH-BW) (xxx=275-355, in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1, maximum system voltage of 1500 V dc, model series: SKTxxx-60BMH (xxx=295-335, in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-60P (60P-BW/60P-BB) (xxx=260-295, in steps of 5), Fuse rating 20A or maximum system voltage of 1500 V dc, model series: SKTxxx-60PH(60PH-BW) (xxx=260-295 in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-144M (144M-BW/144M-BB) (xxx=360-480, in steps of 5), Fuse rating 20A or maximum system voltage of 1500 V dc, model series: SKTxxx-144MH(144MH-BW) (xxx=360-480 in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1, maximum system voltage of 1500 V dc, model series: SKTxxx-144BMH (xxx=380-470 in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-144M (144M-BW/144M-BB) (xxx=510-580, in steps of 5), Fuse rating 30A or maximum system voltage of 1500 V dc, model series: SKTxxx-144MH(144MH-BW) (xxx=510-580 in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1, maximum system voltage of 1500 V dc, model series: SKTxxx-144BMH (xxx=510-580 in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-132M (132M-BW/132M-BB) (xxx=355-385, in steps of 5), Fuse rating 20A or maximum system voltage of 1500 V dc, model series: SKTxxx-132MH(132MH-BW) (xxx=355-385 in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-132M (132M-BW/132M-BB) (xxx=475-520, in steps of 5), Fuse rating 30A or maximum system voltage of 1500 V dc, model series: SKTxxx-132MH (132MH-BW) (xxx=475-520 in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1, maximum system voltage of 1500 V dc, model series: SKTxxx-132BMH (xxx=475-520 in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1, maximum system voltage of 1500 V dc, model series: SKTxxx-120BMH (xxx=325-390 in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-120M (120M-BW/120M-BB) (xxx=310-400, in steps of 5), Fuse rating 20A or maximum system voltage of 1500 V dc, model series: SKTxxx-120MH (120MH-BW) (xxx=310-400 in steps of 5), Fuse rating 20A.



Certificate: 80097185
Project: 80097185

Master Contract: 603246
Date Issued: 2021-09-09

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-120M (120M-BW/120M-BB) (xxx=430-470, in steps of 5), Fuse rating 30A or maximum system voltage of 1500 V dc, model series: SKTxxx-120MH(120MH-BW) (xxx=430-470 in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1, maximum system voltage of 1500 V dc, model series: SKTxxx-120BMH (xxx=430-470 in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-150M (150M-BW/150M-BB) (xxx=480-535, in steps of 5), Fuse rating 20A or maximum system voltage of 1500 V dc, model series: SKTxxx-150MH(150MH-BW) (xxx=480-535 in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-156M (156M-BW/156M-BB) (xxx=425-500, in steps of 5), Fuse rating 20A or maximum system voltage of 1500 V dc, model series: SKTxxx-156MH(156MH-BW) (xxx=425-500 in steps of 5), Fuse rating 20A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1 or 2, maximum system voltage of 1000 V dc, model series: SKTxxx-108M(108M-BW/108M-BB) (xxx=390-410, in steps of 5), Fuse rating 30A or maximum system voltage of 1500 V dc, model series: SKTxxx-108MH(108MH-BW) (xxx=390-410 in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1, maximum system voltage of 1500 V dc, model series: SKTxxx-108BMH (xxx=390-410 in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire class (Canada): Class C, Fire Performance (USA) Type 1, maximum system voltage of 1500 V dc, model series: SKTxxx-156BMH (xxx=465-500 in steps of 5), Fuse rating 20A.

Notes:

1. The electrical characteristics are within ± 3 percent of the indicated values of I_{sc} , V_{oc} , and P_{max} under standard test conditions (irradiance of 100 mW/cm², AM 1.5 spectrum, and a cell temperature of 25°C (77°F)), NOCT: 45°C.
2. The operating ambient temperature of these devices may exceed 40 °C at full load for all wire sizes if it is determined suitable in the field use application.

APPLICABLE REQUIREMENTS

CSA CAN/CSA-C22.2 NO. 61730-1:11 Photovoltaic (PV) module safety qualification - Part 1: Requirements for construction - First Edition 2011-08; Update No. 1: October 2013.

CSA CAN/CSA-C22.2 NO. 61730-1:11 Photovoltaic (PV) module safety qualification - Part 1: Requirements for construction - First Edition, Amendment 1:2013 to CAN/CSA-C22.2 No. 61730-1:11 October 2013.

CSA CAN/CSA-C22.2 NO. 61730-1:11 Photovoltaic (PV) module safety qualification - Part 1: Requirements for construction - First Edition, Amendment 2:2015 to CAN/CSA-C22.2 No. 61730-1:11 February 2015.

CSA CAN/CSA-C22.2 NO. 61730-2:11 Photovoltaic (PV) module safety qualification - Part 2: Requirements for testing - First Edition 2011-08; Update No. 1: October 2013.

CSA CAN/CSA-C22.2 NO. 61730-2:11 Photovoltaic (PV) module safety qualification - Part 2: Requirements for testing - First Edition, Amendment 1:2013 to CAN/CSA-C22.2 No. 61730-2:11 October 2013.

UL 61730-1 1st: Photovoltaic (PV) Module Safety Qualification – Part 1: Requirements for Construction, 2017-12-04, revision date 2020-04-30.

UL 61730-2 1st: Photovoltaic (PV) Module Safety Qualification – Part 2: Requirements for Testing, 2017-12-04, revision date 2020-04-30.

MARKINGS

Each unit shall bear all the required markings identified in the applicable certification report(s).